

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING NO: 7165-0061:102 Page 1 of 1

CATEGORY: Control Unit (Non High Rise)

LISTEE: Chemetron, 4801 Southwick Drive, 3<sup>rd</sup> Floor, Matteson, IL 60443  
Contact: Gary Kimble (708) 283-4447

DESIGN: Model Micro I-EV (Version 3.51 or 3.61) releasing device control unit. Local, automatic, manual releasing device services. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature rating and FM label.

APPROVAL: Listed as releasing device control unit for use with separately listed compatible initiating and indicating devices. 45 seconds delay in trouble annunciator for supervising AC power circuitry is not approved.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7140-0061:102



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager